

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

MARSHA L. BROWN
PRESIDENT

PEDRO BIRBA
VICE-PRESIDENT

VAN AMBATIELOS
HELENA JUBANY
ELENORE A. WILLIAMS

CITY OF LOS ANGELES
CALIFORNIA



ANTONIO R. VILLARAIGOSA
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

ANDREW A. ADELMAN, P.E.
GENERAL MANAGER

RAYMOND CHAN
EXECUTIVE OFFICER

DOC'S Marketing Corporation
4121 Guardian Street
Simi Valley, CA 93063

RESEARCH REPORT: RR 25654
(CSI # 06060)

BASED UPON ICC ES EVALUATION
LEGACY REPORT NO.ER-5367

Attn: Forrest Dockery
(805) 583-9911

REEVALUATION DUE DATE:
April 1, 2008

GENERAL APPROVAL - I-LAG™ Brand Eye Lag Screws and Wire System.

DETAILS

The above assemblies and products are approved when in compliance with the description, use, identification and findings of Legacy Report No.ER-5367 dated March 1, 2006, of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The approval is subject to the following conditions:

1. Allowable loads shall not be increased due to duration of load such as wind or earthquake.
2. Fasteners are embossed with four "I" 's radiating from the shank on the top portion of the washer as shown in Figure 1. Each box of fasteners has a label bearing the I-LAG brand name, the manufacturer's name and address, the fastener type, the quantity and the ICC-ES report number (ER-5367).
3. Fasteners are installed in accordance with the manufacturer's instructions and this report.
4. Calculations demonstrating that applied loads comply with this report shall be prepared by a licensed engineer or architect registered in the State of California.

RR 25654
Page 1 of 2

DOC'S Marketing Corporation
Re: I-LAG™ Brand Eye Lag Screws and Wire System

DISCUSSION

The approval is based on tests.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

YEUAN CHOU, Chief
Engineering Section
2319 Dorris Place
Los Angeles, CA 90031
Phone (213) 485-2376
Fax (213) 847-0985

YC:elem
RR25654/wp8.0
R03/28/07
5A1/2103.4

Attached: ICC ES Evaluation Legacy Report No. ER-5367 (3 Pages)

RR 25654
Page 2 of 2